

My Company Name


My Address

To: Whitewater Well Services
1248 Brier Park Way
Buffralo, NY
90210
Stewart Bullin

Project: Sieve testing
Pit by TP120

Sieve Analysis Report

Project Number: M11-04-5414
Report Number: 1
Report Date: 13-Apr-11
Copies To: Stewart Bullin
Sample Type: 25mm agg
Sampled By: EGT/SS
Tested By: client
Sample Date: 12-Apr-11
Date Received: 12-Apr-11
Date Tested: 13-Apr-11



Sieve Size (mm)	% Passing	Percent Retained
25.000	100.00	0.00
20.000	92.49	7.51
12.500	58.92	33.57
10.000	47.02	11.90
5.000	24.97	22.05
2.500	16.54	8.43
1.250	12.98	3.56
0.630	10.44	2.54
0.320	6.87	3.57
0.160	2.68	4.19
0.080	0.00	2.68

Per: _____