

My Company Name

My Address


To: NEW CONCRETE LTD.
P.O. BOX 1418
BROCK TOWN
USA

ATTENTION: MR DICK SMITH

Project: 1995 MATERIALS TESTING

Sieve Analysis Report

Project Number: M95-01-107
Report Number: 2
Report Date: 05-Jan-95
Copies To: 2 - CLIENT
Sample Type: CRUSHED GRAVEL
Sampled By: SGI/WS
Tested By: CLIENT
Sample Date: 05-Jan-95
Date Received: 05-Jan-95
Date Tested: 05-Jan-95



Sieve Sizes (mm)	Percent Finer	Percent Retained
10.000	100.00	0.00
5.000	100.00	0.00
2.500	86.28	13.72
1.250	69.12	17.16
0.630	46.93	22.19
0.315	17.39	29.54
0.160	8.11	9.28
0.080	5.82	2.29

PLUS 5mm
MATERIAL SCREENED OFF
CRUSHED GRAVEL

Per: _____