

My Company Name

My Street Address
 My City and State or Province
 My Zip / Postal Code
 My Phone My FAX

To: Kpa Developemts
 Some Town
 USA

Project: Investigations for new subdivision



Atterberg Report

Project Number: BXO-138-854
 Report Number: 2
 Report Date: 5/27/01
 Copies To: Engineer, Owner
 Authorized By: Manager
 Performed By: Tech
 Bore #: 12
 Sample #: 33
 Bore Date: 5/16/01
 Sample Depth: 22
 Preparation (Wet/Dry): wet

Natural

Plastic Limit	Tare #	4	31	29
	Tare Weight	15.79	15.35	15.79
	Tare + Wet Soil	24.12	24.69	24.12
	Tare + Dry Soil	22.01	22.32	22.01
	Wt. of Moisture	2.11	2.37	2.11
	Wt. of Dry Soil	6.22	6.97	6.22
	Moisture Content %	33.9	34.0	33.9

Liquid Limit	Tare #	13	8	23
	Tare Weight	15.52	16.22	15.87
	Tare + Wet Soil	27.74	25.69	27.53
	Tare + Dry Soil	22.83	21.82	22.75
	No. of Blows	29	24	23
	Wt. of Moisture	4.91	3.87	4.78
	Moisture Content %	67.2	69.1	69.5



Liquid Limit	69	Natural Moisture Content	33.9	Other tests being performed on this sample: Organic Content, Grain Size, Proctor
Plastic Limit	34	Classification of Sample	OH	
Plasticity Index	35			
Method A				

Wet Moist

Per: _____