

My Company Name

My Company Address

To: LMT Enterprises Ltd.
 P.O. Box 173
 Dunmore, AB
 T0J 1A0


Terry Meier

Project: PMA Asphalt Mix Design
 Allowance Overpass



Sieve Analysis Report

Project Number: LMT
Report Number: 1
Report Date: 10-Apr-03
Sample Type: me
Sampled By: EGT
Source: site
Sample Date: 09-Apr-03
Date Received: 10-Apr-03
Date Tested: 10-Apr-03
Tested By: EGT
Copies To: us



Sieve Size (mm)	% Passing	Spec. Low (%)	Spec. High (%)
12.50	100.00		
10.00	99.16	100.00	100.00
5.00	63.92	90.00	95.00
2.50	42.52	70.00	76.00
1.25	29.16		
0.63	22.09		
0.32	15.92		
0.16	10.57	8.00	16.00
0.08	6.92	4.00	8.00

FM = 4.1

Night Shift
 10mm Asphalt

My Company Name _____